

⚠ DANGER



Hazardous voltage.
Will cause severe injury or death.

The line side of main is energized when off.

Turn off power at utility before working inside this section.

900P02SH01 R1

NO SCREW
WIRE BEHIND
⚡⚡⚡

EATON | Cutler-Hammer

POW-R-LINE[®]
Switchboard

Volts	480Y/277 V	G. D. No.	SHL11035
Phase	3	Wire	4
Frequency	60 Hz	Item No.	003
Mid. Air	SES	Section No.	1 Of 3
		Date	5/21/2008
Current Ratings - Amperes			
Supply	800	Neut.	800
Section	800	Neut.	800
Enclosure Type	1		

This Section is Rated For Use On A Circuit Capable Of Delivering Not More Than 65 KA RMS Sym Amperes, 480 Volts maximum, When Protected By A Current Limiting Main Device, A N/A Ampere Maximum Class N/A Fuse Or A Type N/A Circuit Breaker Rated Not More Than N/A Amperes Must Be Used.

The Short Circuit Rating Of This Switchboard Section is Equal To The Lowest Rating Of (1) Any Section Electrically Connected In Series Or (2) Any Installed Panelboard Having A Marked Short Circuit Rating Or (3) Any Device Installed Except As Noted In The Series Rating Information Manual Attached Or (4) 42KA Max For Any Lineup Containing An RDRDC Feeder Device Mounted On Distribution Chassis.

If This Section Contains A Control Transformer, The Secondary Voltage is 120V.

If This Section Contains A Bonded Neutral, The Bonding Means Shall Only Be Removed For Test Purposes.

Cutler-Hammer Made in USA 900P02SH01 R9

NOTICE

NEUTRAL DISCONNECT LOCATED IN THIS SECTION.

900P02SH01 R1

L '4 A'
COND